

Facility Summary in ROSEBUD County in the City of ASHLAND

Location: ST LABRE INDIAN SCHOOL UST
1000 TONGUE RIVER RD
ASHLAND, MT 59003 ROSEBUD

Sys Fac ID: 44-00701

Last Inspected On: 9/3/2013

Operating Permit Renewal Date: 12/28/2016

Contact: Leney Mcnac, (406) 666-2215

Owners/Operators: St Labre Indian School, Owner (406)-666-2215 1000 TONGUE RIVER RD
ASHLAND MT 59003

Dana Davis, UST Class A Operator
Leney Mcnac, UST Class A Operator
Ronald Messman, UST Class A Operator
Dana Davis, UST Class B Operator
Dana Davis, UST Class B Global Operator
Leney Mcnac, UST Class B Global Operator
Ronald Messman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	22	12/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1957			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/3/2013	Automatic Tank Gauging 0.2	Deferred	
15,000					

Facility Summary in ROSEBUD County in the City of ASHLAND

Location: WESTERN PUMP
US HIGHWAY 212
ASHLAND, MT 59003 ROSEBUD
Contact: (406) 784-2500

Sys Fac ID: 44-01892
Last Inspected On: 11/18/2014
Operating Permit Renewal Date: 12/31/2017

Owners/Operators: Cleatus Stevenson, Owner (406)-784-2400 PO BOX 436
ASHLAND MT 59003-0436
James Stevenson, UST Class A Operator
James Stevenson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	2/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3098			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, Deferred	
2,000					
2	23	2/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3099			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, Deferred	
8,000					
3	18	10/29/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3100			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/18/2014	Stat. Inventory Reconciliation	Stat. Inventory Reconciliation, Deferred	
4,000					

Facility Summary in ROSEBUD County in the City of ASHLAND

Location: CHEYENNE DEPOT 2
US HIGHWAY 212 & MISSION RD
ASHLAND, MT 59003 ROSEBUD

Sys Fac ID: 44-13200

Last Inspected On: 3/6/2015

Operating Permit Renewal Date:

Contact: Cecilia Parker, (406) 784-2522

Owners/Operators: Northern Cheyenne Tribe, Owner

(406)-477-6794

ECONOMIC DEVELOPMENT COMMITTEE
PO BOX 10
LAME DEER MT 59043-0010

Christie Avery, UST Class A Operator
Ruthie Biglethand, UST Class A Operator
Carrie Braine, UST Class A Operator
Stoney Elkshoulder, UST Class A Operator
Raymond Holmes, UST Class A Operator
Jonathan Limpy Jr, UST Class A Operator
Chris Risingsun, UST Class A Operator
Chahoristah Rowland, UST Class A Operator
Zhona Tang, UST Class A Operator
Carrie Braine, UST Class B Operator
Stoney Elkshoulder, UST Class B Operator
Raymond Holmes, UST Class B Operator
Jonathan Limpy Jr, UST Class B Operator
Christie Avery, UST Class B Global Operator
Ruthie Biglethand, UST Class B Global Operator
Carrie Braine, UST Class B Global Operator
Raymond Holmes, UST Class B Global Operator
Jonathan Limpy Jr, UST Class B Global Operator
Chris Risingsun, UST Class B Global Operator
Chahoristah Rowland, UST Class B Global Operator
Zhona Tang, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

Facility Summary in ROSEBUD County in the City of ASHLAND

Location: CHEYENNE DEPOT 2
US HIGHWAY 212 & MISSION RD
ASHLAND, MT 59003 ROSEBUD
Contact: Cecilia Parker, (406) 784-2522

Sys Fac ID: 44-13200
Last Inspected On: 3/6/2015
Operating Permit Renewal Date:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	7/30/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4420			None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Gasoline		3/6/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		11/26/2005			
2	22	7/30/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4421			None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Gasoline		3/6/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		11/26/2005			
3	22	7/30/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4422			None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Diesel		3/6/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		11/26/2005			

Facility Summary in ROSEBUD County in the City of COLSTRIP

Location: COLSTRIP 500 KV SUBSTATION
COLSTRIP 500 KV SUBSTATION
COLSTRIP, MT 59323 ROSEBUD

Sys Fac ID: 44-01432

Last Inspected On: 4/18/2013

Operating Permit Renewal Date: 7/12/2016

Contact: Beth Stimatz, (406) 497-2687

Owners/Operators: Northwestern Energy, Owner

(406)-497-3382

ATTN: BETH STIMATZ
40 E BROADWAY ST
BUTTE MT 59701-9394

John Habeger, UST Class A Operator

Darren Brockel, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	33	4/30/1982	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3998		7/6/2012	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Not Listed	
2,500					

Facility Summary in ROSEBUD County in the City of COLSTRIP

Location: COLSTRIP STEAM ELECTRIC STATION UNITS 3 & 4
601 WILLOW AVE UNITS 3 & 4
COLSTRIP, MT 59323 ROSEBUD

Sys Fac ID: 44-06584

Last Inspected On: 3/31/2015

Operating Permit Renewal Date:

Contact: Mike Holzwarth, (406) 748-5046

Owners/Operators: Talen Montana LLC, Owner (406)-237-6900 303 N 28TH ST SUITE 400
BILLINGS MT 59101
Michael Holzwarth, Operator (406)-748-5046 PO BOX 38
COLSTRIP MT 59323-0038
Michael Holzwarth, UST Class A Operator
William Neumiller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	36	5/1/1979	Unknown	Steel	
3703	Yes		None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		3/31/2015	Deferred	MLLD Line Tightness Testing	
500,000					
5	36	5/1/1979	Unknown	Steel	
2863	Yes		None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		3/31/2015	Deferred	MLLD Line Tightness Testing	
40,000					

Facility Summary in ROSEBUD County in the City of COLSTRIP

Location: TOWN PUMP INC COLSTRIP
112 WILLOW AVE
COLSTRIP, MT 59323 ROSEBUD

Sys Fac ID: 44-08689
Last Inspected On: 3/7/2013
Operating Permit Renewal Date: 4/27/2016

Contact: Kevin Kenneally, (406) 748-3533

Owners/Operators: Town Pump of Hardin Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Daniel Sampson, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	40	4/12/1975	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4787			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/5/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000		6/2/2006			
2	40	4/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4788			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/5/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		7/2/2006			
3	40	4/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4789			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/5/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		7/2/2006			

Facility Summary in ROSEBUD County in the City of COLSTRIP

Location: TOWN PUMP INC COLSTRIP
112 WILLOW AVE
COLSTRIP, MT 59323 ROSEBUD

Contact: Kevin Kenneally, (406) 748-3533

Sys Fac ID: 44-08689
Last Inspected On: 3/7/2013
Operating Permit Renewal Date: 4/27/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	40	4/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4790			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/5/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		10/14/2006			
5	40	4/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4791			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/5/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000		10/14/2006			
6	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4792			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/15/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		10/25/2006			
7	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4793			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/15/2009	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000		10/25/2006			

Facility Summary in ROSEBUD County in the City of COLSTRIP

Location: COLSTRIP STEAM ELECTRIC STATION WILLOW AVE
601 WILLOW AVE
COLSTRIP, MT 59323 ROSEBUD

Sys Fac ID: 44-08921

Last Inspected On: 5/9/2014

Operating Permit Renewal Date: 8/22/2017

Contact: James Parker, (406) 748-5046

Owners/Operators: Talen Montana LLC, Owner (406)-237-6900 303 N 28TH ST SUITE 400
BILLINGS MT 59101
Michael Holzwarth, Operator (406)-748-5046 PO BOX 38
COLSTRIP MT 59323-0038
Michael Holzwarth, UST Class A Operator
William Neumiller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2864			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline		3/30/2011	Manual Interstitial Monitor	Deferred	
10,000					
2	24	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2865			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel		3/30/2011	Manual Interstitial Monitor	Deferred	
10,000					

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: FORSYTH WATERING HOLE
1017 FRONT ST
FORSYTH, MT 59327 ROSEBUD
Contact: Jeremy Smith, (308) 280-0330

Sys Fac ID: 44-01244
Last Inspected On: 9/4/2015
Operating Permit Renewal Date: 12/13/2018

Owners/Operators: RRR Properties LLC, Owner/Operator (308)-280-0330 PO BOX 606
OGALLALA NE 69153

Cory Boyd, UST Class A Operator
DeAnne Jonas, UST Class A Operator
Mike Simpson, UST Class A Operator
Cory Boyd, UST Class B Operator
DeAnne Jonas, UST Class B Global Operator
Mike Simpson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	24	2/24/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1393			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/4/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		11/18/2014	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
5	24	2/24/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1394			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/4/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		11/18/2014	TLS-350/Gilbarco EMC , Veeder Root		
6	24	2/24/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1395			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/4/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		11/18/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: ROSEBUD COUNTY ROAD DEPT
US HIGHWAY 10
FORSYTH, MT 59327 ROSEBUD
Contact: Virgil Farris, (406) 356-2261

Sys Fac ID: 44-01288
Last Inspected On: 10/29/2014
Operating Permit Renewal Date: 1/14/2018

Owners/Operators: Rosebud County Road Dept, Owner (406)-346-2261 PO BOX 1117
FORSYTH MT 59327-1117
Dawne Buck, UST Class A Operator
Wayne Buck, UST Class A Operator
Dawne Buck, UST Class B Operator
Wayne Buck, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	24	4/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1859			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/29/2014	Continuous Interstitial Monitor	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
2	24	4/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1860			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/29/2014	Continuous Interstitial Monitor	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
4	24	4/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1858			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/29/2014	Continuous Interstitial Monitor	Deferred	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: ROSEBUD HEALTH CARE CENTER
383 N 17TH AVE
FORSYTH, MT 59327 ROSEBUD

Sys Fac ID: 44-05262

Last Inspected On: 4/12/2013

Operating Permit Renewal Date: 4/20/2016

Contact: Robert Gregory, (406) 356-2161

Owners/Operators: Rosebud Health Care Center, Owner

(406)-356-2161

383 17TH AVE N
FORSYTH MT 59327

Tim Davis, UST Class A Operator

Michael P Jerhoff, UST Class A Operator

Tim Davis, UST Class B Global Operator

Michael P Jerhoff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	24	9/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4343			Double-Walled	none	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		2/12/2013	Manual Interstitial Monitor	MLLD Line Tightness Testing	
500		2/12/2013			

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: PRINCE INC FORSYTH
W FRONTAGE RD
FORSYTH, MT 59327 ROSEBUD
Contact: BC Prince, (406) 356-2137

Sys Fac ID: 44-06209
Last Inspected On: 11/18/2014
Operating Permit Renewal Date: 2/12/2018

Owners/Operators: Prince Inc, Owner (406)-356-2137 PO BOX 440
FORSYTH MT 59327-0440
Charlee Prince, UST Class A Operator
Charlee Prince, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	17	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4532			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/18/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Not Listed	
10,000		11/21/2011			
6	17	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4533			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/18/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
5,000		11/21/2011			

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: TOWN PUMP INC FORSYTH
974 FRONT ST
FORSYTH, MT 59327 ROSEBUD
Contact: Kevin Kenneally, (406) 356-7952

Sys Fac ID: 44-09356
Last Inspected On: 3/7/2013
Operating Permit Renewal Date: 4/27/2016

Owners/Operators: Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Daniel Sampson, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
11	13	10/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4736			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		12/3/2009			
12	13	10/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4737			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		12/3/2009			
13	13	11/20/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4755			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		12/3/2009			

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: TOWN PUMP INC FORSYTH
974 FRONT ST
FORSYTH, MT 59327 ROSEBUD

Sys Fac ID: 44-09356

Last Inspected On: 3/7/2013

Operating Permit Renewal Date: 4/27/2016

Contact: Kevin Kenneally, (406) 356-7952

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
14	13	10/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4738			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		12/3/2009			
15	13	11/20/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4756			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		12/3/2009			
16	13	11/20/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4757			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		12/3/2009			